

Restarted Simulated Annealing Particle Swarm Optimization Algorithm For Solving Optimal Reactive Power Dispatch Problem

K. Lenin^{1*}, Dr.B.Ravindranath Reddy² & Dr.M.Surya Kalavathi³

^{1*}Research Scholar

Assistant Professor

Sree Sastha College of Engineering

²Deputy Executive Engineer

Jawaharlal Nehru Technological University Kukatpally

Hyderabad 500 085, India.

³Professor of Electrical and Electronics Engineering

Jawaharlal Nehru Technological University Kukatpally

Hyderabad 500 085, India.

Accepted 28 June, 2014

ABSTRACT

This paper presents an algorithm for solving the multi-objective reactive power dispatch problem in a power system. Modal analysis of the system is used for static voltage stability assessment. Loss minimization and maximization of voltage stability margin are taken as the objectives. Generator terminal voltages, reactive power generation of the capacitor banks and tap changing transformer setting are taken as the optimization variables. Evolutionary algorithm and Swarm Intelligence algorithm (EA, SI), a part of Bio inspired optimization algorithm, have been widely used to solve numerous optimization problem in various science and engineering domains. Particle swarm optimization (PSO) is a population-based swarm intelligence algorithm that shares many similarities with evolutionary computation techniques. However, the PSO is driven by the simulation of a social psychological metaphor motivated by collective behaviours of bird and other social organisms instead of the survival of the fittest individual. In this paper we proposed a hybrid restarted simulated annealing particle swarm optimization (RSAPSO) technique to find global minima more efficiently and robustly. The proposed RSAPSO combines the global search ability of PSO and the local search ability of RSA, and offsets the weaknesses of each other. In order to evaluate the proposed algorithm, it has been tested on IEEE 30 bus system and compared to other algorithms reported those before in literature. Results show that (RSAPSO) is more efficient than others for solution of single-objective ORPD problem.

Keywords: global search, local search, simulated annealing, particle swarm optimization, optimal reactive power, Transmission loss.

1. Introduction

Optimal reactive power dispatch problem is one of the difficult optimization problems in power systems. The sources of the reactive power are the generators, synchronous condensers, capacitors, static compensators and tap changing transformers. The problem that has to be solved in a reactive power optimization is to determine the required reactive generation at various locations so as to optimize the objective function. Here the reactive power dispatch problem involves best utilization of the existing generator bus voltage magnitudes, transformer tap setting and the output of reactive power sources so as to minimize the loss and to enhance the voltage stability of the system. It involves a non linear optimization problem. Various mathematical techniques have been adopted to solve this optimal reactive power dispatch problem. These include the gradient method (Alsac, and Scott, 1973; Lee *et al*, 1985), Newton method (Monticelli *et al*, 1987) and linear programming (Deeb and Shahidehpur, 1990; Mangoli and Lee, 1993)]. The gradient and Newton methods suffer from the difficulty in handling inequality constraints. To apply linear programming, the input- output function is to be expressed as a set of linear functions which may lead to loss of accuracy. Recently Global Optimization techniques such as genetic algorithms have been proposed to solve the reactive power flow problem (Paranjothi and Anburaja, 2002); Devaraj and Yeganarayana, 2005).

In recent years, the problem of voltage stability and voltage collapse has become a major concern in power system planning and operation. To enhance the voltage stability,

voltage magnitudes alone will not be a reliable indicator of how far an operating point is from the collapse point (Canizares *et al*, 1996). The reactive power support and voltage problems are intrinsically related. Hence, this paper formulates the reactive power dispatch as a multi-objective optimization problem with loss minimization and maximization of static voltage stability margin (SVSM) as the objectives. Voltage stability evaluation using modal analysis (Canizares *et al*, 1996) is used as the indicator of voltage stability. Particle swarm optimization (PSO) is a computational method that optimizes a problem by iteratively trying to improve a candidate solution with regard to a given measure of quality (Arumugam *et al*, 2009). It is commonly known as meta heuristic method as it makes few or no assumptions about the problem being optimized and can search very large spaces of candidate solutions. PSO does not use the gradient of the problem being optimized, which means PSO does not require for the optimization problem to be differentiable as is required by classic optimization methods such as gradient descent and quasi-Newton methods. PSO can therefore also be used on optimization problems that are partially irregular, noisy, adaptive, etc (Zhang *et al*, 2010). PSO is widely applied in various fields. Lin *et al*, (2009) proposed an immune PSO with functional link based neuro-fuzzy network for image backlight compensation. Fan *et al*. (n.d) integrates the PSO and entropy matching estimator to seek the optimal parameter of the generalized Gaussian distribution mixture model. Zahara *et al*, (2005) used PSO to obtain the optimal thresholding of multilevel image segmentation. Zhang *et al*, (2010) proposed an adaptive

chaotic PSO for magnetic resonance brain image classification. Samanta *et al*, (2009) integrated PSO to artificial neural networks (ANN) and support vector machine (SVM) for machinery fault detection, and demonstrated the results of PSO is superior to the ones of genetic algorithm. Zhang *et al*, (2010) proposed a neural network by PSO for remote-sensing image classification. Unfortunately, PSO is easy to be trapped into local minima and its calculation efficiency is low. In the worst case, when the best solution found by the group and the particles are all located at the same local minimum, it is almost impossible for particles to jump out and do further searching due to the velocity update equation (Kumar and Balasubramanian, 2009). The reason lies in the fact that PSO is powerful of global search but weak on local search. Therefore, our strategy is to introduce in a local search which is applied during each update cycle. In this study, simulated annealing (SA) was chosen as the local search method. SA comes from annealing in metallurgy (Nakib *et al*, (2007), a technique involving heating and controlled cooling of a material to increase the size of its crystals and reduce their defects (Mohamadi *et al*, (2008). The heat causes the atoms to become unstuck from their initial positions (a local minimum of the internal energy) and wander randomly through states of higher energy; the slow cooling gives them more chances of finding configurations with lower internal

energy than the initial one (Rubenthaler *et al*, 2009). Moreover, we introduced in the restarted simulated annealing (RSA) technique to improve the performance of SA. The hybrid algorithm combines both global search provided by PSO and local search provided by RSA (Zhang *et al*, 2011). The performance of (RSAPSO) has been evaluated in standard IEEE 30 bus test system and the results analysis shows that our proposed approach outperforms all approaches investigated in this paper. The performance of (RSAPSO) has been evaluated in standard IEEE 30 bus test system and the results analysis shows that our proposed approach outperforms all approaches investigated in this paper.

Voltage Stability Evaluation

A. Modal analysis for voltage stability evaluation

Modal analysis is one of the methods for voltage stability enhancement in power systems. In this method, voltage stability analysis is done by computing eigen values and right and left eigen vectors of a jacobian matrix. It identifies the critical areas of voltage stability and provides information about the best actions to be taken for the improvement of system stability enhancements. The linearized steady state system power flow equations are given by.

$$\begin{bmatrix} \Delta P \\ \Delta Q \end{bmatrix} = \begin{bmatrix} J_{P\theta} & J_{Pv} \\ J_{Q\theta} & J_{Qv} \end{bmatrix} \begin{bmatrix} \Delta\theta \\ \Delta V \end{bmatrix} \quad (1)$$

Where

ΔP = Incremental change in bus real power.

ΔQ = Incremental change in bus reactive

Power injection

$\Delta\theta$ = incremental change in bus voltage angle.

ΔV = Incremental change in bus voltage Magnitude

$J_{P\theta}, J_{Pv}, J_{Q\theta}, J_{Qv}$ jacobian matrix are the sub-matrixes of the System voltage stability is affected by both P and Q. However at each operating point we keep P constant and evaluate voltage stability by considering incremental relationship between Q and V.

To reduce (1), let $\Delta P = 0$, then.

$$\Delta Q = [J_{Qv} - J_{Q\theta} J_{P\theta}^{-1} J_{Pv}] \Delta V = J_R \Delta V \quad (2)$$

$$\Delta V = J^{-1} - \Delta Q \quad (3)$$

Where,

$$J_R = (J_{Qv} - J_{Q\theta} J_{P\theta}^{-1} J_{Pv}) \quad (4)$$

J_R is called the reduced Jacobian matrix of the system.

B. Modes of Voltage instability:

Voltage Stability characteristics of the system can be identified by computing the eigen values and eigen vectors.

Let,

$$J_R = \xi \Lambda \eta \quad (5)$$

Where,

ξ = right eigenvector matrix of J_R

η = left eigenvector matrix of J_R

Λ = diagonal eigen value matrix of J_R and

$$J_{R^{-1}} = \xi \Lambda^{-1} \eta \quad (6)$$

From (3) and (6), we have

From (3) and (6), we have

$$\Delta V = \xi \Lambda^{-1} \eta \Delta Q \quad (7)$$

Or

$$\Delta V = \sum_i \frac{\xi_i \eta_i}{\lambda_i} \Delta Q \quad (8)$$

Where ξ_i is the i th column right eigenvector and η the i th row left eigenvector of J_R .

λ_i is the i th eigen value of J_R .

The i th modal reactive power variation is,

$$\Delta Q_{mi} = K_i \xi_i \quad (9)$$

Where,

$$K_i = \sum_j \xi_{ij}^2 - 1 \quad (10)$$

Where,

ξ_{ji} is the j th element of ξ_i

The corresponding i th modal voltage variation is

$$\Delta V_{mi} = [1/\lambda_i] \Delta Q_{mi} \quad (11)$$

It is seen that, when the reactive power variation is along the direction of ξ_i the corresponding voltage variation is also along the same direction and magnitude is amplified by a factor which is equal to the magnitude of the inverse of the i th eigen value. In this sense, the magnitude of each eigen value λ_i determines the weakness of the corresponding modal

voltage. The smaller the magnitude of λ_i , the weaker will be the corresponding modal voltage. If $|\lambda_i| = 0$ the i th modal voltage will collapse because any change in that modal reactive power will cause infinite modal voltage variation.

In (8), let $\Delta Q = e_k$ where e_k has all its elements zero except the k th one being 1. Then,

$$\Delta V = \sum_i \frac{\eta_{ik} \xi_i}{\lambda_i} \quad (12)$$

η_{ik} is the element of η

V-Q sensitivity at bus k

$$\frac{\partial V_k}{\partial Q_k} = \sum_i \frac{\eta_{ik} \xi_i}{\lambda_i} = \sum_i \frac{P_{ki}}{\lambda_i} \quad (13)$$

III. Problem Formulation

The objectives of the reactive power dispatch problem considered here is to minimize the system real power loss and maximize the static voltage stability margins (SVSM). This objective is achieved by proper adjustment of reactive power variables like generator voltage magnitude (g_i) V, reactive power generation of capacitor bank (Q_{ci}), and transformer tap setting (tk). Power flow equations are the equality

constraints of the problems, while the inequality constraints include the limits on real and reactive power generation, bus voltage magnitudes, transformer tap positions and line flows.

A. Minimization of Real Power Loss

It is aimed in this objective that minimizing of the real power loss (P_{loss}) in transmission lines of a power system. This is mathematically stated as follows.

$$P_{loss} = \sum_{k=1}^n g_k (V_i^2 + V_j^2 - 2V_i V_j \cos \theta_{ij}) \quad (14)$$

Where n is the number of transmission lines, g_k is the conductance of branch k , V_i and V_j are voltage magnitude at bus i and bus j , and θ_{ij} is the voltage angle difference between bus i and bus j .

B. Minimization of Voltage Deviation

It is aimed in this objective that minimizing of the Deviations in voltage magnitudes (VD) at load buses. This is mathematically stated as follows.

Minimize VD =

$$\sum_{k=1}^{nl} |V_k - 1.0| \quad (15)$$

Where nl is the number of load busses and V_k is the voltage magnitude at bus k .

C. System Constraints

In the minimization process of objective functions, some problem constraints which one is equality and others are

$$P_{Gi} - P_{Di} - V_i \sum_{j=1}^{nb} V_j \begin{bmatrix} G_{ij} & \cos \theta_{ij} \\ +B_{ij} & \sin \theta_{ij} \end{bmatrix} = 0, i = 1, 2, \dots, nb \quad (16)$$

$$Q_{Gi} - Q_{Di} - V_i \sum_{j=1}^{nb} V_j \begin{bmatrix} G_{ij} & \cos \theta_{ij} \\ +B_{ij} & \sin \theta_{ij} \end{bmatrix} = 0, i = 1, 2, \dots, nb \quad (17)$$

where, nb is the number of buses, P_G and Q_G are the real and reactive power of the generator, P_D and Q_D are the real and reactive load of the generator, and G_{ij} and B_{ij} are the mutual conductance and susceptance between bus i and bus j . Generator bus voltage (V_{Gi}) inequality constraint:

$$V_{Gl}^{min} \leq V_{Gi} \leq V_{Gl}^{max}, i \in ng \quad (18)$$

Load bus voltage (V_{Li}) inequality constraint:

$$V_{Ll}^{min} \leq V_{Li} \leq V_{Ll}^{max}, i \in nl \quad (19)$$

Switchable reactive power compensations (Q_{Ci}) inequality constraint:

$$Q_{Ci}^{min} \leq Q_{Ci} \leq Q_{Ci}^{max}, i \in nc \quad (20)$$

Reactive power generation (Q_{Gi}) inequality constraint:

$$Q_{Gl}^{min} \leq Q_{Gi} \leq Q_{Gl}^{max}, i \in ng \quad (21)$$

Transformers tap setting (T_i) inequality constraint:

$$T_i^{min} \leq T_i \leq T_i^{max}, i \in nt \quad (22)$$

Transmission line flow (S_{Li}) inequality constraint:

$$S_{Ll}^{min} \leq S_{Li} \leq S_{Ll}^{max}, i \in nl \quad (23)$$

Where, nc , ng and nt are numbers of the switchable reactive power sources, generators and transformers.

IV. Particles Swarm Optimization

PSO is a population based stochastic optimization technique, which simulates the social behaviour of a swarm of bird, flocking bees, and fish schooling. By randomly initializing the algorithm with candidate solutions, the PSO successfully leads to a global optimum. This is achieved by an iterative procedure based on the processes of movement and intelligence in an evolutionary system.

inequality had to be met. Objective functions are subjected to these constraints shown below.

Load flow equality constraints:

The optimal algorithm of basic particle swarm:

Supposing in the D-dimensional objects searching space, there is a community composed of N particle. The "I" particle represent a D-dimensional vector,

$X_i = (X_{i1}, X_{i2}, \dots, X_{id})$ It means that the "i" particle represents its position in this space. Every position of particle "X" is a potential solution. If we put "x" into objective function, we can know the adaptive value. We can know whether the "x" is the optimal answer based on the adaptive value. The speed of particle is also a D-dimensional, it also recorded as $v_i = (v_{i1}, v_{i2}, \dots, v_{id})$. We record the particle I to the h times, the optimal

position was $P_i = (P_{i1}, P_{i2}, \dots, P_{id})$. All the particles to the h times, the optimal position was $P_{gd} = (P_{g1}, P_{g2}, \dots, P_{gd})$.

$$v_{id}^{t+1} = wv_{id}^t + c_1r_1^t(P_{id}^t - x_{id}^t) + c_2r_2^t(P_{gd}^t - x_{id}^t) \quad (24)$$

$$x_{id}^{t+1} = x_{id}^t + v_{id}^{t+1} \quad (25)$$

Where, C_1 & C_2 : Speeding coefficient, adjusting the maxim step length that flying the best particle in whole situation and the individual best particle respectively. Appropriate C_1 and C_2 speed up the convergence and avoid falling into partial optimality r_1 & r_2 : Random number between 0 and 1, for controlling the weight of speed W : Inertia factor. It was oriented toward overall searching. The population of particles is then moved according to (24) and (25), and tends to cluster together from different directions. However, a maximum velocity v_{max} , should not be exceeded by any particle to keep the search within a meaningful solution space. The PSO algorithm runs through these processes iteratively until the termination criterion is satisfied (A. Mahmood (2010).

$$pert(T) = k \times T \times r_3 \quad (26)$$

Here r_3 is a random value between 0 and 1 with uniform distribution. The temperature T decreases with each iteration of the algorithm, thus reducing the size of the perturbations as the search progresses. This mechanism produces large perturbation in the initial stages of the search and ensures that the resulting parameters are fine tuned towards the end of the optimization (Zhang *et al*, 2009).

$$P = \begin{cases} 1 & \text{if } F(X_n) < F(X_c) \\ \exp\left(\frac{F(X_c) - F(X_n)}{T}\right) & \text{otherwise} \end{cases} \quad (27)$$

In order to avoid getting trapped at local extreme points, the reduction rate of T should be slow enough. In this study the following method to reduce the temperature has been used:

Here T_0 is the initial temperature, β is the reduction constant, and n is the number of iterations. In total, most worsening moves may be accepted at initial stages, but at the final stage only improving ones are likely to be allowed. This can help the procedure jump out of a local minimum. However, sometimes it is better to move back to a former solution that

$$T_n = T_0 \times \beta^n \quad (28)$$

VI. Hybrid Rsapso Technique

Traditional PSO algorithm suffers from getting trapped at the early stage. On the other side, RSA accepts a worse solution so it can escape from local point, resist earliness convergence, and increase the diversity of PSO (Zhang *et al*, 2010). Therefore, a new hybrid strategy was proposed which is referred to as RSAPSO. The proposed algorithm makes full use

The basic formulas are as follows:

V. Restarted Simulated Annealing

The SA algorithm is a probabilistic hill-climbing technique that is based on the annealing/cooling process of metals (Cosola *et al*, 2008). This annealing process occurs after the heat source is removed from a molten metal and its temperature starts to decrease. At each temperature level the energy of the metal molecules reduces, and the metal becomes more rigid. The procedure continues until the metal temperature has reached the surrounding ambient temperature, at which stage the energy has reached its lowest value and the metal is perfectly solid (McGookin *et al*, 2006). The SA procedure begins by generating an initial solution at random. At initial stages, a small random change is made in the current solution X_c . The new solution is called X_n . The perturbation depends on a temperate parameter T , and a scaling constant k .

A move is made to the new solution X_n if it has better energy F or if the probability function has a higher value than a randomly generated number. Otherwise a new solution is generated, evaluated and compared again. The probability p of accepting a new solution X_n which called "Metropolis law" is given as follows:

was significantly better rather than always moving from the current state. This process is called "restarting" of SA (Cretu and Pop, 2009). To do this we set the temperature to a former value and restart the annealing schedule. The decision to restart can be based on several criteria, including whether a fixed number of steps had passed, whether the current energy being too high from the best obtained so far, or randomly restart. In this paper, we restart the SA when the current energy is too high from the best energy because it performs best among all criterions (Gheyas and Smith, 2010).

of the exploration ability both of PSO and of RSA and offsets the weaknesses of each other.

RSAPSO Algorithm for reactive power dispatch problem:

- Step 1 Initialize the population randomly;
- Step 2 Evaluate each particle's fitness function f ;

Step 3 Halve the population randomly: one half was updated by PSO as the formula (24)(25), the other half was updated by SA as the formula (26)(27)(28);

Step 4 Repeat Step 2 and Step 3 until the termination criteria were satisfied;

Step 5 Output the final results.

VII. Simulation Results

The validity of the proposed Algorithm technique is demonstrated on IEEE-30 bus system. The IEEE-30 bus system has

6 generator buses, 24 load buses and 41 transmission lines of which four branches are (6-9), (6-10), (4-12) and (28-27) - are with the tap setting transformers. The real power settings are taken from (Alsac and Scott, 1973). The lower voltage magnitude limits at all buses are 0.95 p.u. and the upper limits are 1.1 for all the PV buses and 1.05 p.u. for all the PQ buses and the reference bus.

Table 1. Voltage Stability Under Contingency State

Sl.No	Contingency	ORPD Setting	Vscrpdp Setting
1	28-27	0.14	0.1422
2	4-12	0.1658	0.1662
3	1-3	0.1784	0.1754
4	2-4	0.2012	0.2032

Table 2. Limit Violation Checking of State variables

State variables	limits		ORPD	VSCRDP
	Lower	upper		
Q1	-20	152	1.3422	-1.3269
Q2	-20	61	8.99	9.8232
Q5	-15	49.92	25.92	26.001
Q8	-10	63.52	38.82	40.802
Q11	-15	42	2.93	5.002
Q13	-15	48	8.1025	6.033
V3	0.95	1.05	1.0372	1.0392
V4	0.95	1.05	1.0307	1.0328
V6	0.95	1.05	1.0282	1.0298
V7	0.95	1.05	1.0101	1.0152
V9	0.95	1.05	1.0462	1.0412
V10	0.95	1.05	1.0482	1.0498
V12	0.95	1.05	1.04	1.0466
V14	0.95	1.05	1.0474	1.0443
V15	0.95	1.05	1.0457	1.0413
V16	0.95	1.05	1.0426	1.0405
V17	0.95	1.05	1.0382	1.0396
V18	0.95	1.05	1.0392	1.04
V19	0.95	1.05	1.0381	1.0394
V20	0.95	1.05	1.0112	1.0194
V21	0.95	1.05	1.0435	1.0243
V22	0.95	1.05	1.0448	1.0396
V23	0.95	1.05	1.0472	1.0372
V24	0.95	1.05	1.0484	1.0372
V25	0.95	1.05	1.0142	1.0192
V26	0.95	1.05	1.0494	1.0422
V27	0.95	1.05	1.0472	1.0452
V28	0.95	1.05	1.0243	1.0283
V29	0.95	1.05	1.0439	1.0419
V30	0.95	1.05	1.0418	1.0397

Table 3. Comparison Of Real Power Loss

Method	Minimum loss
Evolutionary programming[30]	5.0159
Genetic algorithm[31]	4.665
Real coded GA with Lindex as SVSM[32]	4.568
Real coded genetic algorithm[33]	4.5015
Proposed RSAPSO method	4.1163

VIII. Conclusion

In this paper a novel approach RSAPSO algorithm used to solve optimal reactive power dispatch problem, considering various generator constraints, has been successfully applied. The performance of the proposed algorithm demonstrated through its voltage stability assessment by modal analysis is effective at various instants following system contingencies. Also this method has a good performance for voltage stability Enhancement of large, complex power system networks. The effectiveness of the proposed method is demonstrated on IEEE 30-bus system.

References

- O.Alsac, and B. Scott (1973), "Optimal load flow with steady state security", IEEE Transaction. PAS, pp. 745-751.
- Lee K Y ,Paru Y M , Oritz J L (1985)-A united approach to optimal real and reactive power dispatch , IEEE Transactions on power Apparatus and systems: PAS-104 : 1147-1153
- A.Monticelli, M .V.F Pereira ,and S. Granville (1987), "Security constrained optimal power flow with post contingency corrective rescheduling" , IEEE Transactions on Power Systems: PWRS-2, No. 1, pp.175-182
- Deeb N ,Shahidehpur S.M (1990), Linear reactive power optimization in a large power network using the decomposition approach. IEEE Transactions on power system: 5(2): 428-435
- E. Hobson (1980), 'Network constrained reactive power control using linear programming, 'IEEE Transactions on power systems PAS -99 (4) ,pp 868-877,
- K.Y Lee ,Y.M Park, and J.L Oritz, "Fuel -cost optimization for both real and reactive power dispatches", IEE Proc; 131C,(3), pp. 85-93.
- M.K. Mangoli, and K.Y. Lee (1993), "Optimal real and reactive power control using linear programming", Electr. Power Syst. Res, Vol.26, pp.1-10.
- S.R.Paranjothi and K.Anburaja (2002), "Optimal power flow using refined genetic algorithm", Electr. Power Compon. Syst, Vol. 30, 1055-1063.
- D. Devaraj, and B. Yeganarayana (2005), "Genetic algorithm based optimal power flow for security enhancement", IEEE proc-Generation. Transmission and. Distribution; 152.
- C.A. Canizares, A.C.Z. de Souza and V.H. Quintana (1996), "Comparison of performance indices for detection of proximity to voltage collapse ," vol. 11. no.3 , pp.1441-1450.
- M.S. Arumugam, M.V.C. Rao, A.W.C. Tan (2009), A novel and effective particle swarm optimization like algorithm with extrapolation technique, Applied Soft Computing, 9, 308-320.
- Y. Zhang, J. Yan, G. Wei, L. Wu (2010), Find multi-objective paths in stochastic networks via chaotic immune PSO, Expert Systems with Applications, 37, 1911-1919.
- C.-J. Lin, Y.-C. Liu (2009), Image backlight compensation using neurofuzzy networks with immune particle swarm optimization, Expert Systems with Applications, 36 ,5212-5220.
- E. Zahara, S.-K.S. Fan, D.-M. Tsai (2005), Optimal multi-thresholding using a hybrid optimization approach, Pattern Recognition Letters, 26, 1082-1095.
- Y. Zhang, S. Wang, L. Wu (2010), A Novel Method for Magnetic Resonance Brain Image Classification based on Adaptive Chaotic PSO, Progress in Electromagnetics Research, 109, 325-343.
- B. Samanta, C. Nataraj (2009), Use of particle swarm optimization for machinery fault detection, Engineering Applications of Artificial Intelligence, 22, 308-316.
- Y. Zhang, S. Wang, L. Wu (2010), PSO used for Remote-Sensing Image Classification, Journal of Computational Information Systems, 6, 4417- 4425.
- V. Kumar, P. Balasubramanian (2009), Kinetic parameter estimation in hydrocracking using hybrid particle swarm optimization, Fuel, 88, 2171-2180.
- A. Nakib, H. Oulhadj, P. Siarry (2007), Image histogram thresholding based on multiobjective optimization, Signal Processing, 87, 2516-2534.
- H. Mohamadi, J. Habibi, M.S. Abadeh, H. Saadi (2008), Data mining with a simulated annealing based fuzzy classification system, Pattern Recognition, 41, 1824-1833.
- S. Rubenthaler, T. Rydén, M. Wiktorsson (2009), Fast simulated annealing in with an application to maximum likelihood estimation in state-space models, Stochastic Processes and their Applications, 119, 1912- 1931.
- Y. Zhang, S. Wang, L. Wu, Y. Huo (2011), Artificial Immune System for Protein folding model, Journal of Convergence Information Technology, 6, 55-61.
- A. Mahmood (2010), Replicating web contents using a hybrid particle swarm optimization, Information Processing & Management, 46, 170-179.
- E. Cosola, K. Genovese, L. Lamberti, C. Pappalètere (2008), A general framework for identification of hyper-elastic membranes with moiré techniques and multi-point simulated annealing, International Journal of Solids and Structures, 45, 6074-6099.
- E.W. McGookin, D.J. Murray-Smith (2006), Submarine manoeuvring controllers' optimisation using simulated annealing and genetic algorithms, Control Engineering Practice, 14, 1-15.
- Y. Zhang, L. Wu, N. Naggaz, S. Wang, G. Wei (2009), Remote-sensing Image Classification Based on an Improved Probabilistic Neural Network, Sensors, 9, 7516-7539.
- N. Cretu, M.-I. Pop (2009), Acoustic behavior design with simulated annealing, Computational Materials Science, 44, 1312-1318.
- I.A. Gheyas, L.S. Smith (2010), Feature subset selection in large dimensionality domains, Pattern Recognition, 43, 5-13.

29. Wu Q H, Ma J T (1995). Power system optimal reactive power dispatch using evolutionary programming. IEEE Transactions on power systems; 10(3): 1243-1248.
30. S.Durairaj, D.Devaraj, P.S.Kannan (2006),' Genetic algorithm applications to optimal reactive power dispatch with voltage stability enhancement', IE(I) Journal-EL Vol 87.
31. D.Devaraj (2007),' Improved genetic algorithm for multi-objective reactive power dispatch problem' European Transactions on electrical power ; 17: 569-581.
32. P. Aruna Jeyanthi and Dr. D. Devaraj (2010), "Optimal Reactive Power Dispatch for Voltage Stability Enhancement Using Real Coded Genetic Algorithm" International Journal of Computer and Electrical Engineering, Vol. 2, No. 4, 1793-8163.